


DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
JANUARY 2022

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.37	0.09	0.57	1.29	0.09	52	7.1	0.8	0.54	0	AM
2	1.39	0.08	0.54	1.31	0.09	52	7.1	0.8	0.56	0	AM
3	1.37	0.08	0.57	1.23	0.10	52	7.1	0.8	0.54	0	KD
4	1.36	0.09	0.61	1.18	0.09	52	7.1	0.8	0.60	0	KD
5	1.44	0.09	0.53	1.28	0.10	51	7.0	0.9	0.53	0	AM
6	1.45	0.10	0.55	1.29	0.10	50	7.0	0.8	0.54	0	AM
7	1.41	0.09	0.57	1.27	0.11	50	7.0	0.8	0.53	0	AM
8	1.38	0.10	0.55	1.26	0.10	51	7.1	0.8	0.55	0	KD
9	1.46	0.10	0.52	1.29	0.10	51	7.0	0.8	0.51	0	AM
10	1.44	0.08	0.54	1.27	0.10	51	7.1	0.8	0.53	0	AM
11	1.39	0.10	0.58	1.25	0.12	50	7.0	0.7	0.56	0	AM
12	1.45	0.09	0.57	1.20	0.11	50	7.2	0.9	0.65	0	KD
13	1.39	0.07	0.58	1.16	0.09	50	7.1	0.8	0.64	0	KD
14	1.34	0.09	0.54	1.17	0.11	50	7.1	0.8	0.56	0	KD
15	1.32	0.08	0.57	1.19	0.12	51	7.1	0.9	0.44	0	CT
16	1.50	0.08	0.44	1.24	0.10	52	7.2	0.9	0.58	0	CT
17	1.43	0.08	0.60	1.34	0.11	50	7.1	0.8	0.65	0	KD
18	1.38	0.08	0.58	1.37	0.10	50	7.0	0.9	0.55	0	KD
19	1.40	0.06	0.56	1.26	0.10	51	7.1	1.0	0.44	0	CT
20	1.47	0.07	0.49	1.33	0.14	50	7.1	0.9	0.45	0	CT
21	1.40	0.09	0.43	1.32	0.10	50	7.0	1.0	0.33	0	CT
22	1.49	0.07	0.57	1.38	0.11	48	7.3	0.8	0.49	0	RC
23	1.52	0.07	0.61	1.30	0.10	51	7.2	0.8	0.54	0	RC
24	1.38	0.08	0.46	1.36	0.11	51	7.1	0.9	0.48	0	CT
25	1.43	0.10	0.56	1.34	0.11	52	7.2	0.8	0.52	0	CT
26	1.45	0.08	0.50	1.35	0.11	50	7.3	0.8	0.56	0	RC
27	1.28	0.08	0.54	1.26	0.12	50	7.3	1.0	0.53	0	RC
28	1.45	0.09	0.57	1.30	0.12	51	7.2	0.9	0.55	0	RC
29	1.42	0.09	0.53	1.30	0.14	51	7.2	0.8	0.46	0	CT
30	1.40	0.10	0.65	1.29	0.15	51	7.2	0.8	0.49	0	CT
31	1.28	0.08	0.54	1.21	0.12	51	7.3	0.9	0.55	0	RC
AVG.	1.41	0.08	0.55	1.28	0.11	51	7.1	0.8	0.53	0	
MAX.	1.52	0.10	0.65	1.38	0.15	52	7.3	1.0	0.65	0	
MIN.	1.28	0.06	0.43	1.16	0.09	48	7.0	0.7	0.33	0	


2/3/22
Alan E. Stark, Coordinating Engineer Date
Illinois ROINC # 84789479

DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
FEBRUARY 2022

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.39	0.08	0.60	1.26	0.11	51	7.2	1.0	0.54	0	RC
2	1.39	0.09	0.56	1.26	0.12	50	7.1	0.8	0.56	0	CT
3	1.35	0.09	0.55	1.29	0.14	51	7.1	0.9	0.57	0	CT
4	1.33	0.08	0.55	1.29	0.12	50	7.2	0.9	0.57	0	CT
5	1.31	0.09	0.51	1.32	0.11	45	7.3	0.8	0.54	0	RC
6	1.30	0.08	0.55	1.16	0.12	47	7.3	0.9	0.54	0	RC
7	1.36	0.08	0.59	1.23	0.09	46	7.2	0.7	0.54	0	CT
8	1.35	0.09	0.46	1.14	0.11	46	7.1	0.8	0.56	0	CT
9	1.31	0.07	0.58	1.30	0.09	45	7.2	0.9	0.51	0	RC
10	1.23	0.08	0.54	1.22	0.09	46	7.3	0.8	0.51	0	RC
11	1.23	0.08	0.55	1.23	0.11	47	7.2	0.8	0.52	0	RC
12	1.35	0.09	0.54	1.30	0.10	45	7.0	0.9	0.53	0	AM
13	1.46	0.09	0.56	1.32	0.10	46	7.0	0.9	0.56	0	AM
14	1.40	0.10	0.58	1.34	0.11	46	7.0	0.8	0.52	0	AM
15	1.42	0.09	0.53	1.36	0.10	47	7.0	1.1	0.46	0	CT
16	1.44	0.10	0.55	1.32	0.10	46	7.0	0.9	0.51	0	AM
17	1.46	0.10	0.52	1.38	0.11	45	7.4	0.8	0.51	0	AM
18	1.41	0.10	0.53	1.34	0.10	43	7.5	0.8	0.47	0	AM
19	1.48	0.08	0.54	1.42	0.10	44	7.5	0.8	0.54	0	KD
20	1.34	0.08	0.50	1.35	0.10	44	7.5	0.9	0.52	0	KD
21	1.39	0.10	0.57	1.36	0.11	44	7.7	0.9	0.53	0	AM
22	1.37	0.09	0.59	1.33	0.10	43	7.8	0.9	0.55	0	AM
23	1.54	0.08	0.57	1.34	0.11	45	7.5	0.8	0.57	0	KD
24	1.30	0.08	0.59	1.29	0.11	43	7.5	0.8	0.57	0	KD
25	1.41	0.08	0.58	1.33	0.10	44	7.5	0.8	0.63	0	KD
26	1.48	0.09	0.55	1.36	0.12	41	7.7	0.7	0.55	0	BM
27	1.35	0.09	0.57	1.36	0.10	40	7.7	0.7	0.55	0	BM
28	1.45	0.07	0.59	1.34	0.11	43	7.6	0.8	0.59	0	KD
AVG.	1.38	0.09	0.55	1.31	0.11	45	7.3	0.8	0.54	0	
MAX.	1.54	0.10	0.60	1.42	0.14	51	7.8	1.1	0.63	0	
MIN.	1.23	0.07	0.46	1.14	0.09	40	7.0	0.7	0.46	0	

Alan E. Stark
Alan E. Stark, Coordinating Engineer
Illinois ROINC # 84789479
Date *3/4/22*